

SI No	Equipments Description	Class	Frequency of Physical Inspection	Frequency of PMP	Accuracy (+/- )	PMP Lead time (in Hours)	Break Down Lead Time (in Hours)	Avaiability
1	SYSTEM 11	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
2	SYSTEM 12	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
3	SYSTEM 13	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
4	SYSTEM 14	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
5	SYSTEM 15	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
6	SYSTEM 16	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
7	SYSTEM 17	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
17	BOTTOM ASH SYSTEM	B	Weekly	Monthly	0.50%	4	1	98%(hourly)
18	WET SYSTEM	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
19	PD PUMP # 1	A	Daily	Monthly	0.50%	8	2	98%(hourly)
20	UNIT # 1 ZIM CONTROLER	A	Daily	Monthly	0.50%	4	2	98%(hourly)
21	PLC ROOM CLEANING	B	Weekly	Monthly		2	1	98%(hourly)
22	SYSTEM 21 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
23	SYSTEM 21 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
24	SYSTEM 21 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
25	SYSTEM 21 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
26	SYSTEM 21 SLAVE V5	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
27	SYSTEM 21 SLAVE V6	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
28	SYSTEM 22 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
29	SYSTEM 22 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
30	SYSTEM 22 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
31	SYSTEM 22 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
32	SYSTEM 22 SLAVE V5	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
33	SYSTEM 22 SLAVE V6	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
34	SYSTEM 23 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
35	SYSTEM 23 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
36	SYSTEM 23 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
37	SYSTEM 23 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
38	SYSTEM 24 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
39	SYSTEM 24 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
40	SYSTEM 24 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
41	SYSTEM 24 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
42	SYSTEM 25 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)

43	SYSTEM 25 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
44	SYSTEM 25 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
45	SYSTEM 25 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
46	SYSTEM 26 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
47	SYSTEM 26 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
48	SYSTEM 26 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
49	SYSTEM 26 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
50	SYSTEM 27 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
51	SYSTEM 27 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
52	SYSTEM 27 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
53	SYSTEM 27 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
54	SYSTEM 26 & 27 CROSS OVER VALVE	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
55	BOTTOM ASH SYSTEM	B	Weekly	Monthly	0.50%	4	1	98%(hourly)
56	WET SYSTEM	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
57	PD PUMP # 2	A	Daily	Monthly	0.50%	8	2	98%(hourly)
58	UNIT # 2 ZIM CONTROLER	A	Daily	Monthly	0.50%	4	2	98%(hourly)
59	PLC ROOM CLEANING	B	Weekly	Monthly		2	1	98%(hourly)
60	SYSTEM 31 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
61	SYSTEM 31 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
62	SYSTEM 31 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
63	SYSTEM 31 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
64	SYSTEM 31 SLAVE V5	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
65	SYSTEM 31 SLAVE V6	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
66	SYSTEM 32 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
67	SYSTEM 32 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
68	SYSTEM 32 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
69	SYSTEM 32 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
70	SYSTEM 32 SLAVE V5	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
71	SYSTEM 32 SLAVE V6	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
72	SYSTEM 33 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
73	SYSTEM 33 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
74	SYSTEM 33 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
75	SYSTEM 33 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
76	SYSTEM 34 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
77	SYSTEM 34 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
78	SYSTEM 34 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)

79	SYSTEM 34 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
80	SYSTEM 35 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
81	SYSTEM 35 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
82	SYSTEM 35 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
83	SYSTEM 35 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
84	SYSTEM 36 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
85	SYSTEM 36 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
86	SYSTEM 36 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
87	SYSTEM 36 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
88	SYSTEM 37 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
89	SYSTEM 37 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
90	SYSTEM 37 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
91	SYSTEM 37 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
92	SYSTEM 36 & 37 CROSS OVER VALVE	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
93	BOTTOM ASH SYSTEM	B	Weekly	Monthly	0.50%	4	1	98%(hourly)
94	WET SYSTEM	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
95	PD PUMP # 3	A	Daily	Monthly	0.50%	8	2	98%(hourly)
96	UNIT # 3 ZIM CONTROLER	A	Daily	Monthly	0.50%	4	2	98%(hourly)
97	PLC ROOM CLEANING	B	Weekly	Monthly		2	1	98%(hourly)
98	SYSTEM 42 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
99	SYSTEM 42 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
100	SYSTEM 42 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
101	SYSTEM 42 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
102	SYSTEM 42 SLAVE V5	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
103	SYSTEM 42 SLAVE V6	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
104	SYSTEM 43 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
105	SYSTEM 43 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
106	SYSTEM 43 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
107	SYSTEM 43 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
108	SYSTEM 44 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
109	SYSTEM 44 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
110	SYSTEM 44 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
111	SYSTEM 44 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
112	SYSTEM 45 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
113	SYSTEM 45 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
114	SYSTEM 45 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)

115	SYSTEM 45 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
116	SYSTEM 46 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
117	SYSTEM 46 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
118	SYSTEM 46 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
119	SYSTEM 46 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
120	SYSTEM 47 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
121	SYSTEM 47 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
122	SYSTEM 47 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
123	SYSTEM 47 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
124	SYSTEM 48 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
125	SYSTEM 48 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
126	SYSTEM 48 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
127	SYSTEM 48 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
128	SYSTEM 49 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
129	SYSTEM 49 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
130	SYSTEM 49 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
131	SYSTEM 49 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
132	SYSTEM 48 & 49 CROSS OVER VALVE	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
133	BOTTOM ASH SYSTEM	B	Weekly	Monthly	0.50%	4	1	98%(hourly)
134	WET SYSTEM	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
135	PD PUMP # 4	A	Daily	Monthly	0.50%	8	2	98%(hourly)
136	UNIT # 4 ZIM CONTROLER	A	Daily	Monthly	0.50%	4	2	98%(hourly)
137	PLC ROOM CLEANING	B	Weekly	Monthly		2	1	98%(hourly)
138	SYSTEM 52 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
139	SYSTEM 52 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
140	SYSTEM 52 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
141	SYSTEM 52 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
142	SYSTEM 52 SLAVE V5	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
143	SYSTEM 52 SLAVE V6	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
144	SYSTEM 53 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
145	SYSTEM 53 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
146	SYSTEM 53 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
147	SYSTEM 53 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
148	SYSTEM 54 MASTER V1	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
149	SYSTEM 54 SLAVE V2	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
150	SYSTEM 54 SLAVE V3	A	Weekly	Monthly	0.50%	2	1	98%(hourly)

151	SYSTEM 54 SLAVE V4	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
152	SYSTEM 55 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
153	SYSTEM 55 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
154	SYSTEM 55 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
155	SYSTEM 55 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
156	SYSTEM 56 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
157	SYSTEM 56 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
158	SYSTEM 56 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
159	SYSTEM 56 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
160	SYSTEM 57 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
161	SYSTEM 57 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
162	SYSTEM 57 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
163	SYSTEM 57 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
164	SYSTEM 58 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
165	SYSTEM 58 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
166	SYSTEM 58 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
167	SYSTEM 58 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
168	SYSTEM 59 MASTER V1	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
169	SYSTEM 59 SLAVE V2	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
170	SYSTEM 59 SLAVE V3	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
171	SYSTEM 59 SLAVE V4	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
172	SYSTEM 56,57,58 & 59 CROSS OVER VALVE	B	Weekly	Monthly	0.50%	2	1	98%(hourly)
173	BOTTOM ASH SYSTEM	B	Weekly	Monthly	0.50%	4	1	98%(hourly)
174	WET SYSTEM	A	Weekly	Monthly	0.50%	2	1	98%(hourly)
175	UNIT # 5 ZIM CONTROLER	A	Daily	Monthly	0.50%	4	2	98%(hourly)
176	PLC ROOM CLEANING	B	Weekly	Monthly		2	1	98%(hourly)
177	HCSD SYSTEM	A	Weekly	Monthly	0.50%	8	6	98%(hourly)
188	Slurry System Instruments							
189	Level Measurements Instruments							