

NOTICE INVITING TENDER (NIT)

(Tender Ref. no.: CC24NP014)

The Tata Power Company Limited Invites Tenders through E-Tender Two-Part bidding process from interested bidders (with manufacturing / assembling facilities in India) for the following package required for its Transmission Divisions in Mumbai: -

A. Summary of the tendered packages:

Sr. No.	Description	Tender Reference no.	Bid Guarantee Fee / EMD (Rs.)	Tender Fee (Rs.)
For the following package contact person shall be Mr. Naman Patel (naman.patel@tatapower.com) & Mr. Vivek Mittal (vivek.mittal@tatapower.com)				
1.	Supply & Services for 110KV 40MVAR Capacitor bank at Kalyan Receiving station in Mumbai	CC24NP014	5,00,000 /-	1,000 /-

For additional technical details and Pre-Qualification criteria for the subject works please refer **Section C** below.

B. Guidelines for Participating:

Interested bidders having executed similar projects can participate by submitting the following up to **1500 hrs. Friday, 02nd June 2023**: -

1. Non-Refundable Tender Fee, as indicated in table above, in the form of
 - a. Direct deposit in the following bank account and submit the receipt along with a covering letter clearly indicating the Tender Reference number –
 - Beneficiary Name – The Tata Power Co. Ltd.
 - Bank Name – HDFC Bank Ltd.
 - Branch Name – Fort Branch, Mumbai
 - Address – Maneckji Wadia Building, Nanik Motwani Marg, Fort, Mumbai 400023.
 - Branch Code – 60
 - Bank & Branch Code – 400240015
 - Account No – 00600110000763
 - Account type – CC
 - IFSC Code – HDFC0000060

2. Bidders to also submit duly signed and stamped letter indicating name of authorized person, contact number and e-mail id (mandatory) on Bidder's letterhead. It is mandatory to mention Tender Reference no. in the said letter.

Note: - Once the above-mentioned documents are received, detailed RFQ shall be issued through our e-tender system.

Interested Bidder must get in touch with respective contact person, mentioned above, at Tata Power Sahar Receiving Station, T2 Airport Road, Sahar, Andheri (E), Mumbai 400 059 (Near Leela Hotel) for submitting the documents.

It may be please noted that all future correspondence will be strictly done only with **Interested Bidders** who have done the above steps in time with Authorized Person only through Tata Power E-Tender System.

Earnest Money Deposit (EMD) of **INR 5.00 Lakhs** is not to be submitted now and is required at a later stage along with tender submission in the form of Bank Guarantee.

Section C: Addition technical details: (Please refer the following pages for details).

Bidders Pre-qualifying Requirements for 110KV Capacitor Bank			
S No	Parameter	Tata Power Requirement	Documents To be submitted by Vendor to ascertain meeting of Pre-qualification requirement
1	2	3	4
1	Infrastructure	Bidder must be an OEM of Capacitor units system, having manufacturing facility in India.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	Supply and Experience	<p>Bidder should have supplied minimum 02 nos. of Capacitor bank at 110 kV above voltage level. The system supplied should have been in satisfactory commercial operation for a minimum period of 02 years as on scheduled date of the bid submission.</p> <p>Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.</p>	<p>Supply List & Performance Certificates from the utilities / clients</p> <p>Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.</p>
3	Type Test	<p>The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the equipment / material of the same design.</p> <p>The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test may be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC).</p> <p>In case the type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, then type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material.</p>	<p>Type Test Report.</p> <p>Undertaking that there is no change in design / material of construction (MOC) if Type Test Report older than 5 years but less than 10 years prior to date of bid opening has to be considered (if applicable)</p> <p>Undertaking that type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material, in case type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, (if applicable)</p>
4	Commercial Capability	Average annual turnover of the Vendor for last three financial years shall not be less than Rs. 2 Crore	Copy of audited Balance Sheet and P&L Account to be submitted in this regard.

BILL OF QUANTITY

Sr. No.	Description	Qty Set/nos
1	Design, engineering, manufacture, factory testing, packaging, route survey, transport, delivery to site 110kV, 40MVA _r , 50Hz, 3-phase complete set of capacitor bank as per specifications consisting of following:	
1.1	Capacitor units as per OEM design	1 Lump sum
1.2	Copper wound, current limiting series reactor	6 nos
1.3	Neutral current transformer	2 nos
1.5	Lightning arrestor	3 nos
1.6	Adequate quantity of Interconnecting Copper Bus bar, copper flexible conductor along with its respective clamps, connectors, support insulators and post insulators.	1 Lump sum
1.7	The adequate quantity of the Structural steel with hot dipped galvanization, foundation and fixing bolts and nuts, clamps and any other material required for successful commissioning of complete set of capacitor bank	1 Lump sum
	SPARES	
1	Capacitor units	4 nos
2	Neutral current transformer	1 no
3	Support insulators	1 nos
4	Post insulators	1 nos
5	Lightning Arrestor	1 nos
	SERVICES	
1	Supervisory services during unloading, handling, shifting, erection and installation capacitor bank and its associated equipments at its designated location	1 Lump sum
2	Services for testing and commissioning of capacitor bank with technically qualified resources and relevant testing kit required for testing of complete set of capacitor bank and its associated equipments	1 Lump sum