

By Speed Post

No.J-13011/41/2006-IA.II(T)  
Government of India  
Ministry of Environment & Forests

Paryavaran Bhavan,  
C.G.O. Complex, Lodi Road,  
New Delhi-110003.  
Tel. 2436 2434

Dated the 5<sup>th</sup> April, 2007

To

The Chief Executive  
Coastal Gujarat Power Ltd.,  
Chandralok, 36, Janpath,  
New Delhi-110 001.

CORRIGENDUM

**Sub: 4000 MW Mundra Ultra Mega Thermal Power Project at village Tunda, near Mundra, District Kutchh by M/s Coastal Gujarat Power Ltd. – Environmental Clearance – Regarding.**


The undersigned is directed to refer to your letter no. 03:07:UMPP:CGPL:Mundra dated 22<sup>nd</sup> March, 2007 regarding the subject mentioned above. The contents of the above referred letter have been examined. The conditions no. (iv), (v) and (xviii) stipulated in this ministry's clearance letter of even no. dated 2<sup>nd</sup> March, 2007 are hereby amended to read respectively as follows:

- Condition No. (iv):** Based on the above said modeling study, the locations of intake and outfall point and the mode for drawl of water shall be finalized prior to start of the work on the intake and out fall channels.
- Condition No. (v):** For the activities in the CRZ area, necessary clearance under CRZ Notification, as may be applicable, shall be obtained prior to start the work on such activities.
- Condition No. (xviii):** Suitable system shall be provided to reduce water temperature at the final discharge point so that the resultant rise in the temperature of receiving water does not exceed 7<sup>o</sup> C over and above the ambient temperature of the receiving water body.

All other conditions contained in the environmental clearance letter dated 2<sup>nd</sup> March, 2007 shall remain unchanged.

This issues with the approval of the Competent Authority.

Yours faithfully,



(Dr. S.K. Aggarwal)  
Director

Copy to:-

1. The Secretary, Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi-110001.
2. The Secretary, Environment & Forests Department, Govt. of Gujarat, Sachivalaya, 8<sup>th</sup> Floor, Gandhi Nagar-382010 (Gujarat)
3. The Chairman, Central Electricity Authority, Sewa Bhawan, R.K. Puram, New Delhi-110 066.
4. The Chairman, Gujarat Pollution Control Board, Paryavaran Bhawan, Sector 10-A, Gandhi Nagar-382010.
5. The Chairman, Central Pollution Control Board, Parivesh Bhawan, -CBD-cum-Office Complex, East Arjun Nagar, Delhi-110032.
6. The Chief Conservator of Forests, Western Regional Office, Ministry of Environment & Forests, E-5, Arera Colony, Link Road-3, Ravishankar Nagar, Bhopal-462016.
7. Director (EI), MoEF.
8. Guard File.
9. Monitoring File.

(Dr. S.K. Aggarwal)  
Director