



J-13011/41/2006 - IA. II (T)  
Government of India  
Ministry of Environment & Forests

Tel no: 011- 24367257  
e-mail: w.bharat@nic.in  
Paryavaran Bhavan, C.G.O. Complex,  
Lodi Road, New Delhi -110003.  
Dated: 26.04.2011

**CORRIGENDUM**

**Sub: 4150 MW Mundra Ultra Mega Thermal Power Project at village Tunda, near Mundra, in Kutch District, in Gujarat – reg.**

The undersigned is directed to refer to your letter nos. AK/MOEF/0209/2009/132, dated 02.09.2009; AK/MOEF/0211/2009/136, Dated 02.11.2009; AK/MOEF/1111/2010/176; and AK/MOEF/0903/195, dated 09.03.2011 on the above mentioned subject.

2. The request has been examined and the following changes as given under shall be made in this Ministry's letter of even no. dated 02.03.2007.

a) The figure 4000 MW mentioned in the subject letter shall be now substituted by 4150 MW.

b) At Para No.2, the sentence in the 9<sup>th</sup> line read as 'Total land requirement including land required for MRG system and intake and outfall channels is 1242 Ha which includes 130 ha of forest land', the words "MRG system and" shall be now deleted and at condition no. (ix) the following shall be now added:

*"Land requirement shall be optimized and reduced land earlier meant for MRG system shall be converted into Green Belt".*

c) Under Para No. 3, the condition no. (xi) read as 'Two bi-flue and one single flue stacks of 275 m height each shall be provided with continuous online monitoring equipments. Exit velocity of 25 m/sec shall be maintained' shall now be read as:

*"One tri-flue and one bi-flue flue stacks of 275 m height each shall be provided with continuous online monitoring equipments. Exit velocity of 25 m/sec shall be maintained"*

d) Under Para No.3, the condition no. (xxiv) read as "The proposed configuration of the project (5x800 MW) could be changed provided that the total capacity of the power plant shall not exceed 4000 MW and that no individual unit shall be less than 500 MW", shall be substituted by the following:

*"The proposed generation capacity of the project could be increased only by way of adoption of waste heat recovery and entailing no additional coal and water consumption. The generation capacity thus obtained taking waste heat recovery into account shall however not exceed 4150 MW and configuration of units may be accordingly adopted at 5x830 MW".*


3. After clause no. (xxxii), under Para no.3 of this Ministry's letter of even no. dated 02.03.2007, the following conditions shall be now added:

- xxxiii) Coal transportation from MPSEZ Port to plant site at Mundra shall be by closed conveyor belt system traversing a distance of about 9.10 Km.
- xxxiv) The project proponent shall upload the status of compliance of the conditions stipulated in the environmental clearance issued vide this Ministry's letter of even no. dated 02.03.2007 and its amendment dated 05.04.2007, in its website and updated periodically and also simultaneously send the same by e-mail to the Regional Office of the Ministry of Environment and Forests.
- xxxv) Criteria pollutants levels including NO<sub>x</sub>, RSPM (PM<sub>10</sub> & PM<sub>2.5</sub>), SO<sub>x</sub> (from stack & ambient air) shall be regularly monitored and results displayed in your website and also at the main gate of the power plant.
- xxxvi) An amount of Rs 72.0 Crores shall be earmarked as one time capital cost for CSR programme. Subsequently a recurring expenditure of Rs 14.40 Crores per annum shall be earmarked as recurring expenditure for CSR activities. Details of the activities to be undertaken shall be submitted **within one month** along with road map for implementation.
- xxxvii) It shall be ensured that an in-built monitoring mechanism for the schemes identified under CSR activities are in place and annual social audit shall be got done from the nearest government institute of repute in the region. The project proponent shall also submit the status of implementation of the scheme from time to time.

4. All other conditions mentioned in this Ministry's aforesaid letter of even no. 02.03.2007 and its amendment dated 05.04.2007 shall remain the same.

This issues with the approval of the Competent Authority.

Yours faithfully,


  
(W. Bharat Singh)  
Deputy Director

/ M/s Coastal Gujarat Power Ltd.  
Tata Power Backbay Receiving Station  
148 Lt. Gen J. Bhonsle Marg  
Nariman Point  
**Mumbai - 400 021.**

Copy to:

1. The Secretary, Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi 110001.
2. The Secretary (Environment), Forests and Environment Department Government of Gujarat.
3. The Chairman, Central Electricity Authority, Sewa Bhawan, R.K. Puram, New Delhi-110066.

4. The Chairman, Gujarat State Pollution Control Board, Paryavaran Bhawan, Sector 10-A, Gandhi Nagar- 382010- with a request to display a copy of the clearance letter at the Regional Office, District Industries Centre and Collector's office within 30 days.
5. The Chairman, Central Pollution Control Board, Parivesh Bhawan, CBD-cum-Office Complex, East Arjun Nagar, Delhi- 110032.
6. The Chief Conservator of Forests, Regional Office (WZ), E-5, Kendriya Paryavaran Bhawan, Arera Colony, Ravishankar Nagar, Bhopal - 462016.
7. The District Collector, Kutch District, Govt. of Gujarat.
8. Guard file.

  
(W. Bharat Singh)  
Deputy Director