
CHAPTER - VI

RISK AND CONSEQUENCES ANALYSIS

1. The chlorine tonners are the potential chemical risk for power projects. This risk has been avoided by proposing chlorine gas dosing by the installation of electro chlorination system or chlorine dioxide system at CW sump for marine growth control.