

Availability Calculation for the month of Oct 2025 for NRSS XXXVI Transmission Limited Northern Region																	
Sl. No.	Name of Line	Line Length (CKM)	No. of Sub Conductors(NSC)	Weightage Factor (NSC X CKM)	Total duration Available for Consideration (in Minute) TI	Duration of Outage						Trials (Min)	Wi (Ti-Tnal) / (Ti*Wi)	100*Σ(Wi (Ti-Tnal) / (Ti*Wi)) / ΣWi	No. of Tripping		
						Attributable to Transmission Licensee(NRSS)		Attributable to Others		Attributable to Force Majeure / Natural Claimity / Militancy					Outage Under the Category of Deemed available		Oct'25
					Hrs.	Min.	Hrs.	Min.	Hrs.	Min.	Hrs.	Min.					
1	400KV Neemaran Babai S/C Line	1.542	6	9.25	44640	0	0	0	0	0	0	0	0	9.25	100.00	0	0
2	400KV Babai-Sikar S/C Line	1.542	6	9.25	44640	0	0	0	0	0	0	0	0	9.25	100.00	0	0
3	400KV Babai-Bhiwani Transmission Line Ckt-1	110.962	6	665.77	35968	0	0	0	144	32	202	45	0	665.77	100.00	0	0
4	400KV Babai-Bhiwani Transmission Line Ckt-2	110.962	6	665.77	44640	0	0	0	0	0	3	37	0	665.77	100.00	0	0
														1350.05			

% Availability for NRSS XXXVI Transmission limited for the month of Oct'25 100.00

(Signature)
 (Ajay Kumar)
 NRSS XXXVI Transmission Limited