

RYAPTE POWER TRANSMISSION LIMITED

Registered Office: Plot No. 181, Ground Floor, Block- K, Mangolpuri, Delhi -110083,
CIN- U42202DL2025GOI448817

NOTICE

(Under sub-section (2) of Section 15 of the Electricity Act, 2003)

1. The **RYAPTE POWER TRANSMISSION LIMITED**, having its Registered Office at **PLOT NO. 181, GROUND FLOOR, BLOCK-K, MANGOLPURI, DELHI -110083**, which is incorporated under the Companies Act, 2013, has made an application before the Karnataka Electricity Regulatory Commission, Bengaluru under sub-section (1) of Section 15 of the Electricity Act, 2003 for grant of transmission license in respect of the transmission lines, sub-stations and other assets, the details of which are given.

Sr. No.	Name of the line/ Sub-Station (location)	Approx. Line length/ Capacity**	Quoted Transmission Charges	Schedule COD	Remarks
1	400 kV D/C line from proposed 400/220 kV Ryapte Sub-station to proposed 400/220 kV Doddathaggalli Substation	157* km / 400 kV	₹ 521,07,10,000/- per Annum	30.01.2029	Including 2 Nos 400 kV bays at Kolar SS; 2 Nos 220 kV bays at Ekrajapur SS and 2 Nos 220 kv Bays at Sarjapura SS
2	400 kV D/C line from Kolar Substation to proposed 400/220kV Doddathaggalli Substation along with 2 Nos 400 kV GIS bays at Kolar SS	31 km / 400 kV			
3	220 kV D/C line with Single Zebra and partial 2 runs of 1200 sq.mm UG cable from proposed Doddathaggalli Substation to 220 kV Ekrajapura substation along with 2 Nos. AIS TB at Ekrajapura S/S	17 km / 220 kV			
4	220 kV D/C line with partial AAC Moose and partial 2 runs of 1200 sq.mm UG cable from proposed Doddathaggalli Substation to proposed 220 kV Hosakote new substation	16 km / 220 kV			
5	220 kV D/C line with Single Zebra and partial 2 runs of 1200 sq.mm UG cable from proposed 400/220kV Doddathaggalli Substation to Sarjapura A/S substation with 2 Nos. GIS Bays at Sarjapura S/S	27 km / 220 kV			
6	Establishing 5x500 MVA, 400/220 kV S/s at Ryapte in Tumkur District along with 2x125MVA 400 kV Bus Reactors	400/220 kV			
7	Establishing 3X500 MVA, 400/220kV GIS sub-station at Doddathaggalli (Near Hosakote) along with 2x125 MVA 400 kV Bus Reactors	400/220 kV			

*The estimated route line length in the States of Karnataka and Andhra Pradesh is 107 km and 50 km respectively.

**As considered in bid.

2. Complete application and other documents filed before the Commission are available on the web site <https://www.tatapower.com/regulatory/Regulatory-Files/tcb-projects-tab> for access by any person. The application can also be inspected at the office of the Company at **The Tata Power Company Limited, Shatabdi Bhawan, B-12 & 13, Sector 4, Noida, UP-201301** with **Mr. Kunal Sharma** or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections or suggestions, if any, be filed before the Secretary, **Karnataka Electricity Regulatory Commission, No. 16, C-1, Millers Tank Bed Area, Vasantha Nagar, Bengaluru, Karnataka 560052, Landmark: Near Ambedkar Bhavan** and email at **kerc-ka@nic.in** with a copy of the objection (s) / suggestion (s) to the applicant or its authorized agent, within 15 days of the publication of the notice in the newspaper.

Place: Delhi
Date: 08.08.2026

Sd/-
Kunal Sharma
CEO