

कार्यालय निदेशक (आपरेशन)  
उपरो पॉवर ट्रांसमिशन कारपोरेशन लिमिटेड  
11वां तल, शक्ति भवन विस्तार  
14 अशोक मार्ग, लखनऊ-226001  
दूरभाष : 0522-2287833  
ई मेल : director\_op@upptcl.org



Office of Director (Operation)  
U.P. Power Transmission Corporation Ltd.  
11<sup>th</sup> Floor, Shakti Bhawan Extn.  
14 Ashok Marg, Lucknow-226001  
Contact No. 0522-2287833  
E-Mail ID- director\_op@upptcl.org

No. 3025/Dir(O)/UPERC

Date: 21 June, 2024

Sub:- Recommendation for grant of intra-state transmission license in favor of M/s Jalpura Khurja Power Transmission Limited.

✓ Secretary,  
UP Electricity Regulatory Commission,  
UPERC Bhawan,  
Gomti Nagar, Lucknow.

Sir,

Kindly refer to the petition no. 2079/2024 filed by M/s Jalpura Khurja Power Transmission Limited before Hon'ble UPERC for issue of transmission license to construct the following transmission system-

**A. Construction of 400/220 kV, 2x500 MVA GIS Substation Metro Depot (Gr. Noida) with associated lines.**

- Construction of 400/220 kV, 2x500 MVA GIS substation Metro Depot (Gr. Noida) (alongwith 125 MVAR Bus Reactor)
- LILO of one ckt. of 400 kV Gr. Noida (765 kV)- Pali, Gr. Noida DC line at 400/220 kV GIS S/s Metro Depot (Gr. Noida) (LILO line on 400 kV Double Circuit Monopole & Twin Moose HTLS conductor along with OPGW stringing work)

**B. Construction of 400/220 kV, 2x500 MVA GIS Substation Jalpura (Gr. Noida) with associated lines**

- Construction of 400/220 kV, 2x500 MVA GIS substation Jalpura (Gr. Noida) (alongwith 125 MVAR Bus Reactor)
- 400 kV Jalpura-THDC TPS Khurja DC line (Twin Moose HTLS conductor and Monopole/Narrow Base Tower/Conventional Tower and OPGW stringing work)

In this regard, UPPTCL (State Transmission Utility) would like to submit that above transmission system has been approved by the Energy Task Force (ETF) as well as cabinet. Accordingly and as such, UPPTCL does not have any objection in consideration of issue of transmission license in favor of M/s Jalpura Khurja Power Transmission Limited for construction of transmission system as per approved RFP/TSA.

Your sincerely

(Piush Garg)

Director (Operation)

For State Transmission Utility (STU)

- Cc: 1. PS to Chairman, UPPTCL for kind information of Chairman, UPPTCL, Lucknow.  
2. PS to MD, UPPTCL, Lucknow for kind information of MD, UPPTCL please.  
3. Director (Work & Project), UPPTCL, Lucknow.  
4. Chief Engineer (765 kV DU), UPPTCL, Lucknow.