

Reply to Prebid Queries - Tender No. 4100035733/CC25ADO013 - Outline Agreement (OLA) for 1 year for Supply of Air Circuit Breaker Panels PAN India

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	Tata Power Response
1	2	3	4	5
1	NBS/EV/24/SPEC-2/CONTENT/ Page 1 of 16	Approved Make List	Approved Make List is requested , Approved makes of ACB required.	Approved Make List : L&T ABB Siemens C&S Schenider
2	NBS/EV/24/SPEC-2 /Type Test/Page 11 of 16	All these Type Test should be conducted at CPRI/ERDA.	Can we get Type Test done from NABL Approved LAB.	OK .Accepted . However Panel Manufacturer Will take Ownership Of Supplied Equipment (ACB Panel)for any Defect Liability .
3	NBS/EV/24/SPEC-2 /Type Test/Page 11 of 16	Test	Type Test Mentioned are of ACB , submission of Type Test Report from ACB supplier will be considered as Compliance or we have to get Type Test done on Panels if yes then which all Type Test are mandatory for Panels manufactured.	As ACB is critical Component in panel hence submission of Type Test Report from ACB supplier will be considered as Compliance However Panel Manufacturer Will take Ownership Of Supplied Equipment (ACB Panel)for any Defect Liability .
4	Enclosure : Overall Limiting Dimensions L x W x H (mm)		Pls provide the Tentative Dimensions on GA drawing	Tentative Dimension : 1800+100(H) X 800(W) X 800(D) mm
5	Enclosure : Protection grade of enclosure	IP-54	i.) With Double Door (Inner Door & Outer Door) or Canopy  ii.) With Single Door or Canopy only.	With Single Door with Canopy suitable for Outdoor Application
6	ACB 400A & 630A TP		Pls confirm the make of ACB	Approved Make List : L&T ABB Siemens C&S Schenider
7	Type Test		Pls confirm the Type Test required on your Outdoor type Panel Board IS:8623, IEC 61439 or IEC 60529	Yes , It is Required. As ACB is critical Component in panel hence submission of Type Test Report from ACB supplier will be considered as Compliance However Panel Manufacturer Will take Ownership Of Supplied Equipment (ACB Panel)for any Defect Liability .
8	Acceptance Test		We wanted to confirm whether we can get the Acceptance Test done from any NABL accredited Labs or is there a specific agency you would recommend?	Acceptance test from NABL accredited Labs is Accepted . However Panel Manufacturer Will take Ownership Of Supplied Equipment (ACB Panel)for any Defect Liability .
9	How many Panel Sealed for Acceptance Test		For the Acceptance Test, how many panels would be selected or sealed from a single Lot?	Selected from a Single Lot.

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	Tata Power Response
10	Unloading at Site		Pls confirm that who is organised the Unloading at delivery site, Purchaser or supplier.	Unloading of ACB panel will be in scope of Purchaser / Tata power.