25th November' 2026

CORRIGENDUM-1 to NIT dated 07th October 2026

The Tata Power Company Limited Invites Tenders through E-Tender Two-Part bidding process, from interested bidders (with manufacturing / assembling facilities in India) for the following package required for its Transmission Divisions in Mumbai: -

Vide present Corrigendum-1 to the Notice inviting tender dated 07th October 2026. Following changes are being effected in all 05 LOTs of the tender,

Extension in tender purchase date:

Sr No.	Earlier schedule	Revised schedule
1	1500 Hrs of 16th October 2026	1500 Hrs of 30th November 2026

Please note, above is a Corrigendum to the Tender advertised on 07th October 2026. The bidders who have already participated in the Tender shall be retained as "participant" & they shall not be required to participate again by submitting the Tender Fee of INR 2,000/.

Updated NIT document (Inclusive of Original Tender and Corrigendum 01) is produced below,

A. Summary of the tendered packages:

For the following packages contact person shall be Mr. Naman Patel (naman.patel@tatapower.com) & Mr. Vivek Mittal (vivek.mittal@tatapower.com)

LOT No.	Description	Tender Reference no.	Bid Guarantee Fee / EMD (Rs.)	Tender Fee (Rs.)
1.	Supply, Installation, Testing and Commissioning of 2x90MVA, 110/33KV, Power Transformers for Malad GIS Project	**CC27NP014A (LOT 1)**	20,00,000/-	2000/-
2	Supply, Installation, Testing and Commissioning of 2x125MVA, 220/33KV, Power Transformers for Parel GIS Project.	**CC27NP014B (LOT 2)**		
3	Supply, Installation, Testing and Commissioning of 1x250MVA, 220/110/33 kV, ICT for Parel GIS Project.	**CC27NP014C (LOT 3)**		
4	Supply, Installation, Testing and Commissioning of 2x90MVA, 220/22KV, Power Transformers for Kolshet GIS Project.	**CC27NP014D (LOT 4)**		
5	Supply, Installation, Testing and Commissioning of 01 no. 220KV, 125MVAr Variable Shunt Reactor (40% to 100% variability) for Kolshet GIS Project.	**CC27NP014E (LOT 5)**		

For Pre-Qualification criteria for the subject works please refer **Section C** below.

B. <u>Guidelines for Participating:</u>

Interested bidders having executed similar projects can participate by submitting the following up to **1500 hrs. Monday 30th November 2026**: -

1. Non-Refundable Tender Fee, as indicated in table above, in the form of direct deposit in the following bank account and submit the receipt along with a covering letter clearly indicating the Tender Reference number –

   Beneficiary Name – The Tata Power Co. Ltd.

   Bank Name – HDFC Bank Ltd.

   Branch Name – Fort Branch, Mumbai

   Address – Maneckji Wadia Building, Nanik Motwani Marg, Fort, Mumbai 400023.

Branch Code – 60

Bank & Branch Code – 400240015

Account No – 00600110000763

Account type – CC

IFSC Code – HDFC0000060

2. **Bidders to also submit duly signed and stamped letter indicating name of authorized person, contact number and e-mail id (mandatory) on Bidder's letterhead.**
3. **It is mandatory to mention the Tender Reference no./nos. in the said letter.**

Note: Once the above-mentioned documents are received from Bidders, Tender reference no./Lot wise RFQ will be issued to Bidders through our e-Tender system (ARIBA).

Evaluation Criteria: There is total **05 Nos. "LOT"** in this NIT. Technical and Commercial evaluation of each LOT shall be done independently. Accordingly, award decision shall be made for each lot.

It may be please noted that all future correspondence will be strictly done only with **Interested Bidders** who have done the above steps in time with Authorized Person only through Tata Power E-Tender System.

Earnest Money Deposit (EMD) of **INR 20.00 Lakh** is not to be submitted now and is required at a later stage along with tender submission in the form of Bank Guarantee.

C. Pre-Qualification Criteria (PQR): (Please refer the following pages for details).

1) **PQR for Tender Ref. No. CC27NP014A-** Supply, Installation, Testing and Commissioning of 2x90MVA, 110/33KV, Power Transformers for Malad GIS Project.

Bidders Prequalifying Requirements for 110kV, 90MVA Transformer			
S No	**Parameter**	**Tata Power Requirement**	**Documents To be submitted by Vendor to ascetrain meeting of Pre-qualification requirement**
1	2	3	4
1	**Infrastructure**	Bidder shall be an OEM of power transformer of 110kV Voltage level and above with manufacturing facility / assembly in India. The bidder must have in-house routine and acceptance testing facilities for acceptance as per relevant IS/IEC.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	**Supply and Experience**	Bidder shall have supplied minimum 5 no. Power transformer of 110kV or higher voltage rating,63 MVA or higher capacity in last 10 years. Out of which, minimum 2 no. of power transformer of 63 MVA or higher capacity have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening. "In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder." Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.	Supply List & Performance Certificates from the utilities / clients Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
3	**Type Test**	The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the similar or higher rating equipment / material of the same design. Dynamic short circuit withstand type test report of similar design with same or higher rating transformer are also to be mandatorily submitted with similarity certificate in line with Annexure J of CEA manual " Standard Specifications and technical Parameters for Transformers and Reactors (66 kV & above voltage class)". Incase, bidder doesn't have Dynamic short circuit test report or doesn't meet the similarity criteria,then the bidder shall have successfully supplied and inservice similar transformer in Tata Power trnasmission. Same shall be considered for the comparison of the proposed transformer. The type tests and its duration shall be as per the latest CEA guidelines.	Type Test Report. Undertaking shall be submitted stating that " type tests and its duration shall be as per the latest CEA guidelines".
4	**Commercial Capability**	Average Annual turnover of the bidder for last three years shall not be less than INR 100 crore.	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.
5	**EPC Experience (If applicable)**	In case the package involves installation & commissioning of the equipment / material, then the bidder shall have installed and commissioned minimum 2 no. of power transformer of 125 MVA or higher capacity and should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.	Performance Certificates from the utilities / clients

2) **PQR for Tender Ref. No. CC27NP014B-** Supply, Installation, Testing and Commissioning of 2x125MVA, 220/33KV, Power Transformers for Parel GIS Project.

Bidders Prequalifying Requirements for 220kV, 125MVA Transformer			
S No	**Parameter**	**Tata Power Requirement**	**Documents To be submitted by Vendor to ascetrain meeting of Pre-qualification requirement**
1	2	3	4
1	**Infrastructure**	Bidder shall be an OEM of power transformer of 220kV Voltage level and above with manufacturing facility / assembly in India. The bidder must have in-house routine and acceptance testing facilities for acceptance as per relevant IS/IEC.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	**Supply and Experience**	Bidder shall have supplied minimum 5 no. Power transformer of 220kV or higher voltage rating,125 MVA or higher capacity in last 10 years. Out of which, minimum 2 no. of power transformer of 125 MVA or higher capacity have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening. "In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder." Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.	Supply List & Performance Certificates from the utilities / clients Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
3	**Type Test**	The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the similar or higher rating equipment / material of the same design. Dynamic short circuit withstand type test report of similar design with same or higher rating transformer are also to be mandatorily submitted with similarity certificate in line with Annexure J of CEA manual " Standard Specifications and technical Parameters for Transformers and Reactors (66 kV & above voltage class)". Incase, bidder doesn't have Dynamic short circuit test report or doesn't meet the similarity criteria,then the bidder shall have successfully supplied and inservice similar transformer in Tata Power trnasmission. Same shall be considered for the comparison of the proposed transformer. The type tests and its duration shall be as per the latest CEA guidelines.	Type Test Report. Undertaking shall be submitted stating that " type tests and its duration shall be as per the latest CEA guidelines".
4	**Commercial Capability**	Average Annual turnover of the bidder for last three years shall not be less than INR 100 crore.	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.
5	**EPC Experience (If applicable)**	In case the package involves installation & commissioning of the equipment / material, then the bidder shall have installed and commissioned minimum 2 no. of power transformer of 125 MVA or higher capacity and should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.	Performance Certificates from the utilities / clients

3) **PQR for Tender Ref. No. CC27NP014C-** Supply, Installation, Testing and Commissioning of 1x250MVA, 220/110/33 kV, ICT for Parel GIS Project.

Bidders Prequalifying Requirements for 220kV Transformer / ICT			
S No	**Parameter**	**Tata Power Requirement**	**Documents To be submitted by Vendor to ascetrain meeting of Pre-qualification requirement**
1	2	3	4
1	**Infrastructure**	Bidder shall be an OEM of power transformer of 220kV Voltage level and above with manufacturing facility / assembly in India. The bidder must have in-house routine and acceptance testing facilities for acceptance as per relevant IS/IEC.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	**Supply and Experience**	Bidder shall have supplied minimum 5 no. ICTs of 220kV or higher voltage rating,160 MVA or higher capacity in last 10 years. Out of which, minimum 2 no. of ICT of 160 MVA or higher capacity have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening. "In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder." Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.	Supply List & Performance Certificates from the utilities / clients Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
3	**Type Test**	The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the similar or higher rating equipment / material of the same design. Dynamic short circuit withstand type test report of similar design with same or higher rating transformer are also to be mandatorily submitted with similarity certificate in line with Annexure J of CEA manual " Standard Specifications and technical Parameters for Transformers and Reactors (66 kV & above voltage class)". Incase, bidder doesn't have Dynamic short circuit test report or doesn't meet the similarity criteria,then the bidder shall have successfully supplied and inservice similar transformer in Tata Power trnasmission. Same shall be considered for the comparison of the proposed transformer.	Type Test Report. Undertaking shall be submitted stating that " type tests and its duration shall be as per the latest CEA guidelines".
4	**Commercial Capability**	Average Annual turnover of the bidder for last three years shall not be less than INR 100 crore.	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.
5	**EPC Experience (If applicable)**	In case the package involves installation & commissioning of the equipment / material, then the bidder shall have installed and commissioned minimum 2 no. of ICTs of 160 MVA or higher capacity and should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.	Performance Certificates from the utilities / clients

4) **PQR for Tender Ref. No. CC27NP014D-** Supply, Installation, Testing and Commissioning of 2x90MVA, 220/22KV, Power Transformers for Kolshet GIS Project.

Bidders Prequalifying Requirements for 220kV, 90MVA Transformer			
S No	**Parameter**	**Tata Power Requirement**	**Documents To be submitted by Vendor to ascetrain meeting of Pre-qualification requirement**
1	2	3	4
1	**Infrastructure**	Bidder shall be an OEM of power transformer of 220kV Voltage level and above with manufacturing facility / assembly in India. The bidder must have in-house routine and acceptance testing facilities for acceptance as per relevant IS/IEC.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	**Supply and Experience**	Bidder shall have supplied minimum 5 no. Power transformer of 220kV or higher voltage rating,90 MVA or higher capacity in last 10 years. Out of which, minimum 2 no. of power transformer of 90 MVA or higher capacity have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening. "In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder." Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.	Supply List & Performance Certificates from the utilities / clients Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
3	**Type Test**	The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the similar or higher rating equipment / material of the same design. Dynamic short circuit withstand type test report of similar design with same or higher rating transformer are also to be mandatorily submitted with similarity certificate in line with Annexure J of CEA manual " Standard Specifications and technical Parameters for Transformers and Reactors (66 kV & above voltage class)". Incase, bidder doesn't have Dynamic short circuit test report or doesn't meet the similarity criteria,then the bidder shall have successfully supplied and inservice similar transformer in Tata Power trnasmission. Same shall be considered for the comparison of the proposed transformer. The type tests and its duration shall be as per the latest CEA guidelines.	Type Test Report. Undertaking shall be submitted stating that " type tests and its duration shall be as per the latest CEA guidelines".
4	**Commercial Capability**	Average Annual turnover of the bidder for last three years shall not be less than INR 100 crore.	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.
5	**EPC Experience (If applicable)**	In case the package involves installation & commissioning of the equipment / material, then the bidder shall have installed and commissioned minimum 2 no. of power transformer of 90 MVA or higher capacity and should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.	Performance Certificates from the utilities / clients

5) **PQR for Tender Ref. No. CC27NP014E-** Supply, Installation, Testing and Commissioning of 01 no. 220KV, 125MVAr Variable Shunt Reactor for Kolshet GIS Project.

Bidders Prequalifying Requirements for 220 kV, 125 MVAR, 3 Phase Variable Bus Shunt Reactor (Variability 50 to 125 MVAR)			
S No	**Parameter**	**Tata Power Requirement**	**Documents To be submitted by Vendor to ascetrain meeting of Pre-qualification requirement**
1	2	3	4
1	**Infrastructure**	Bidder or its Principal (parent company) shall be an OEM of Variable Shunt Reactor of 145 kV Voltage level and above with manufacturing facility / assembly in India.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	**Supply and Experience**	Bidder or its Principal shall have supplied minimum 2 nos., 3 phase, 145 kV and above, 100 MVAR or higher capacity Variable Shunt Reactor (40 to 100% variability) in last 10 years. Out of which, minimum 1 no of Variable Shunt Reactor of 100 MVAR or higher capacity should have been in satisfactorily commercial operation for a minimum period of two year as on the date of bid opening. "In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder." Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.	Supply List & Performance Certificates from the utilities / clients Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
3	**Type Test**	The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the Variable Shunt Reactor of the same design and similar or higher rating. The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test can be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC). In case the type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, then type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material.	Type Test Report. Undertaking that there is no change in design / material of construction (MOC) if Type Test Report older than 5 years but less than 10 years prior to date of bid opening has to be considered (if applicable) Undertaking that type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material, in case type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, (if applicable)
4	**Commercial Capability**	Average annual turnover of the Vendor for last three financial years shall not be less than Rs. 100 Crore	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.
5	**EPC Experience (If applicable)**	In case the package involves installation & commissioning of the equipment / material, then the bidder shall have installed and commissioned minimum 2 no. of Reactors of 125 MVAr or higher capacity and should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.	Performance Certificates from the utilities / clients

--XXX--