

## Corrigendum – 1

**The Tata Power Company Limited Invites Tenders** (Two-Part Bidding Process), from interested and eligible Vendors for the following Works required for its various Transmission Receiving Stations.

### **A. Summary of the tendered packages:**

| <b>Tender Enquiry No.</b> | <b>Work Description</b>   | <b>EMD (Rs.)</b> | <b>Tender Participation Fee (Rs.)</b> | <b>Last date and time for Payment of Tender Participation Fee*</b> |
|---------------------------|---|------------------|---------------------------------------|--|
| CC26PRD029                | Supply of 145 kV Current Transformers at Various Transmission Locations in and around Mumbai. (Kalyan, Chola, Borivali, Kalwa, Davdi) | 1,00,000/-       | Rs. 2,000/-                           | 8 <sup>th</sup> May 2026 Up to 3PM.                                |

**Interested bidder is strongly advised not to wait by above time and purchase the tender immediately to get the link for bid submission. This will enable them to communicate/raise queries against the subject tender in time.**

For additional technical details and Pre-qualification criteria for the subject works please refer section C below.

### **B. Guidelines for Participating:**

Interested and eligible vendors can participate by submitting the following up to 1500 hours on Monday – 8<sup>th</sup> May 2026.

1. Payment of non-refundable Tender Fee, as indicated in table above to be paid by direct deposit in following bank account

Beneficiary Name – The Tata Power Co. Ltd.

Bank Name – HDFC Bank Ltd.

Branch Name – Fort Branch, Mumbai

Address – Maneckji Wadia Building, Nanik Motwani Marg, Fort, Mumbai

400023. Branch Code – 60

Bank & Branch Code – 400240015

Account No – 00600110000763

Account type – CC

IFSC Code – HDFC0000060

2. Submission of duly signed and stamped Authorization Letter indicating name of authorized person, contact number and e-mail id (mandatory) on Vendor's letterhead. The letter shall also mandatorily include payment details of Tender fee and Tender Reference no **CC26PRD029**.

Authorization Letter along with proof of submission of tender fee should be e-mail to **Ms. Priyanka Devkar** ([Priyanka.devkar@tatapower.com](mailto:Priyanka.devkar@tatapower.com)) and copy to **Ms. Vaishali Kachare** ([vaishali.Kachare@tatapower.com](mailto:vaishali.Kachare@tatapower.com))

**Note:** - Once the above-mentioned documents are received, detailed RFP shall be issued through our e-tender system.

3. It is clarified that Bid Guarantee/EMD as mentioned in section “A” above, is not required to be submitted at this stage, and it will be required to be submitted in the form of Bank guarantee at the time of Bid Submission.

**C. Addition technical details: Prequalification Criteria (Technical & Commercial):**

| Pre-qualification Requirement Criteria |                       |   |   |
|--|-----------------------|---|---|
| 1                                      | 2                     | 3   | 4   |
| 1                                      | Infrastructure        | <p>Bidder must be OEM for the 145KV &amp; above rating current transformer. Bidders should have Factory / Assembly Unit in India with facility for Routine Testing. Factory / Assembly Unit will be inspected by Tata Power Cross Functional Team (CFT) and acceptance will be at sole discretion of Tata Power.</p>  | <p>Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.</p>  |
| 2                                      | Supply and Experience | <p>Bidder shall have supplied 25 Nos. of Live Tank oil filled Current Transformers with composite insulators of 145 kV or higher voltage class in last 5 years as on date of bid submission.</p> <p>15 Nos of Live Tank oil filled Current Transformers with composite insulators of 145 kV or higher voltage class shall be in satisfactory service for last 2 years as on date of bid submission.</p> <p>“In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder.”</p> <p>Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.</p> | <p>Supply List &amp; Performance Certificates from the utilities / clients</p> <p>Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.</p> |
| 3                                      | Type Test             | <p>The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the equipment / material of the same design.</p> <p>The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test may be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC). Full set type test reports shall be submitted without requirement of any non</p>  | <p>Type Test Report.</p> <p>Undertaking that there is no change in design / material of construction (MOC) if Type Test Report older than 5 years but less than 10 years prior to date of bid opening has to be considered (if applicable)</p>              |

|   |                       |  |   |
|---|-----------------------|--|---|
|   |                       | disclosure agreement.<br><br>In case the type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, then type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material. | Undertaking that type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material, in case type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, (if applicable) |
| 4 | Commercial Capability | Average Annual Turnover of the bidder for last 03 years shall not be less than INR 1 Crore.  | Copy of audited Balance Sheet and P&L Account to be submitted in this regard.   |

|   |
|---|
| <b>Note:</b>  |
| 1) The Prequalification Criteria published along with the tender "In Section C.1 Techno-Commercial PQR" is the total & complete pre-qualification requirement for the tender and shall prevail over any other/additional pre-qualification requirement mentioned elsewhere in the tender.                                     |
| 2) Tata Power reserves the right to review and approve / reject the Bidder based on Document Submission.  |
| 3) In case the bidder has a previous association with any of the Tata Group companies for similar products and services, the performance feedback for that bidder by Tata Group companies shall only be considered for evaluation, irrespective of performance certificates issued by any third organization."                |
| Above Pre-qualification details need not be submitted at this stage. These shall be required to be submitted along with bid submission. At this stage, Interested Vendors who fulfill above criteria need to participate in tender by paying tender fee and submitting authorization letter as detailed in section "B" above. |

**D. Price Bid Format: (BOM)**

| S.No                                      | Description   | Unit | Qty |
|---|---|------|-----|
| <b>Delivery Location: Davdi, Mulshi</b>   |   |      |     |
| 1   | 110KV CT (CT, 4C, OIL, LIVETK, 145KV, 2000-1200-800/5A) | Nos. | 3   |
| <b>Delivery Location: Chola, Thakurli</b> |   |      |     |
| 1   | 110KV CT (CT, 4C, OIL, LIVETK, 145KV, 2000-1200-800/5A) | Nos. | 6   |
| <b>Delivery Location: Kalyan</b>          |   |      |     |

|                                    |  |      |   |
|------------------------------------|--|------|---|
| 1                                  | 110KV CT (CT,4C,OIL,LIVETK,145KV,2000-1200-800/5A) | Nos. | 3 |
| <b>Delivery Location: Borivali</b> |  |      |   |
| 1                                  | 110KV CT (CT,4C,OIL,LIVETK,145KV,1200-800-400/5A)  | Nos. | 2 |
| <b>Delivery Location: Kalwa</b>    |  |      |   |
| 1                                  | CT145KV5CORE,1600-800/1,0.2SPS,                    | Nos. | 6 |