

30<sup>th</sup> June' 2026

**NOTICE INVITING TENDER (NIT)**

**The Tata Power Company Limited Invites Tenders** through E-Tender Two-Part bidding process from interested bidders (with manufacturing / assembling facilities in India) for the following package required for its Transmission Divisions in Mumbai: -

**A. Summary of the tendered packages:**

For the following packages contact person shall be Mr. Naman Patel ([naman.patel@tatapower.com](mailto:naman.patel@tatapower.com)) & Mr. Vivek Mittal ([vivek.mittal@tatapower.com](mailto:vivek.mittal@tatapower.com))

Sr No.	Description	Tender Reference no.	Bid Guarantee Fee / EMD (Rs.)	Tender Fee (Rs.)
1.	Supply, Transportation at site and Supervision Services for 3 Phase, 22 kV, 1.9 Ohms/ph, 12 kA, 10 Sec., 360 Amps Neutral Grounding Transformer (NGT) for Salsette RSS (01 no.) & Trombay RSS (01 no.).	<b>CC27NP009</b>	2,50,000/-	2000/-

For Pre-Qualification criteria for the subject works please refer **Section C** below.

**B. Guidelines for Participating:**

Interested bidders having executed similar projects can participate by submitting the following up to **1500 hrs. Friday 10<sup>th</sup> July 2026:** -

1. Non-Refundable Tender Fee, as indicated in table above, in the form of

Direct deposit in the following bank account and submit the receipt along with a covering letter clearly indicating the Tender Reference number –

Beneficiary Name – The Tata Power Co. Ltd.

Bank Name – HDFC Bank Ltd.

Branch Name – Fort Branch, Mumbai

Address – Maneckji Wadia Building, Nanik Motwani Marg, Fort, Mumbai 400023.

Branch Code – 60

Bank & Branch Code – 400240015

Account No – 00600110000763

Account type – CC

IFSC Code – HDFC0000060

**2. Bidders to also submit duly signed and stamped letter indicating name of authorized person, contact number and e-mail id (mandatory) on Bidder's letterhead.**

**3. It is mandatory to mention the Tender Reference no./nos. in the said letter.**

**Note:** Once the above-mentioned documents are received from Bidders, Tender will be issued to Bidders through our e-Tender system (ARIBA).

It may be please noted that all future correspondence will be strictly done only with **Interested Bidders** who have done the above steps in time with Authorized Person only through Tata Power E-Tender System.

Earnest Money Deposit (EMD) of **INR 2.50 Lakh** is not to be submitted now and is required at a later stage along with tender submission in the form of Bank Guarantee.

**C. Pre-Qualification Criteria (PQR):** (Please refer the following pages for details).

### C.1 Bidders Pre-qualifying requirement for NGT

Sr No	Parameter	Tata Power Requirement	Documents to be submitted by vendor to ascertain meeting of Pre-Qualification Requirement
1	2	3	4
1	<b>Infrastructure</b>	Bidder shall be an OEM of " <b>Neutral Grounding Transformer</b> " with manufacturing facility / assembly in India. The bidder must have in-house routine and acceptance testing facilities for acceptance as per relevant IS/IEC.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	<b>Supply and Experience</b>	<p>Bidder shall have supplied from India minimum "<b>02 Nos</b>" Mineral Oil (MO) filled Neutral Grounding Transformer of 33 kV, 360 AMPs or higher capacity rating in last 10 years. Minimum 1 no. of MO filled NGTs of same rating or higher capacity should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.</p> <p>"In case the bidder has a previous association with Tata Power for similar products and services, the performance feedback for that bidder by Tata Power shall only be considered irrespective of performance certificates issued by any other organization. Technical performance, delivery timelines, service and support records of past executed projects in Tata Power will be considered for technical evaluation of bidder."</p> <p>Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.</p>	<p>Supply List &amp; Performance Certificates from the utilities / clients</p> <p>Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.</p>
3	<b>Type Test</b>	<p>The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the same ratings ( 33 KV) or higher rating MO filled Neutral Grounding Transformer of the same design.</p> <p>The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test can be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC).</p> <p>In case the type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, then type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material.</p>	<p>Type Test Report.</p> <p>Undertaking that there is no change in design / material of construction (MOC) if Type Test Report older than 5 years but less than 10 years prior to date of bid opening has to be considered (if applicable)</p> <p>Undertaking that type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material, in case type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, (if applicable)</p>
4	<b>Commercial Capability</b>	Average Annual turnover of the bidder for last three years shall not be less than INR <b>20 Crore</b> .	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.

BOQ: Supply, Transportation and Supervision Services for NGT for Salsette & Trombay RSS			
Sr No	Type of Transformer	Qty	UoM
1	Design, manufacture, factory testing, packing, route survey, transportation at site, 3 phase, Oil filled, 50 Hz, 22kV, 1.9 Ohms/ph, 12kA, 10 sec, 360 Amps NGT including all accessories as per the specific and general requirements and complete with bushings, cable box, conservator etc. with transformer Oil that includes (filling of transformer, conservator and radiators + 10% extra)	2	Nos.
2	Set of Spares (As per specifications)	2	Lot
3	Freight Charges	2	Nos.
4	Supervision Services for Unloading ,Installation, testing & commissioning	6	Mandays