

The Tata Power Company Limited Invites Tenders through E-Tender Two-Part bidding process from interested bidders (with manufacturing / assembling facilities in India) for the following transmission package required for its Transmission Division: -

Procedure for Participating in Tender

| Tender Enquiry No. | Work Description | EMD (Rs.) | Tender Participation Fee (Rs.) | Last date & time for Payment of Tender Participation Fee* |
|---------------------------|--|------------------|---------------------------------------|--|
| CC25TP050 | Supply of GI Hardware Fittings for upgradation of 110 kV Kalwa Kalyan Line | 1,70,000 /- | 2,000/- | 1500 Hrs. Friday, 14 th November 2025 |

*** Interested bidder is strongly advised not to wait by above time and purchase the tender immediately to get the link for bid submission. This will enable them to communicate/raise queries against the subject tender in time.**

Procedure for Participating in Tender. Following steps to be done before last date for purchase of tender,

- Interested bidder to refer to the Section C: "Pre-Qualification Requirement" (PQR).
- Eligible and Interested Bidder to submit duly signed and stamped letter on Bidder's letterhead indicating,
 - Tender Enquiry number.
 - Name of authorized person.
 - Contact number.
 - e-mail id.
 - Details of submission of Tender Participation Fee.
- Non-Refundable Tender Participation Fee, as indicated in table above, to be submitted in the form of Direct deposit in the following bank account and submit the receipt along with a covering letter clearly indicating the Tender Reference number –

Beneficiary Name – The Tata Power Co. Ltd.

Bank Name – HDFC Bank Ltd.

Branch Name – Fort Branch, Mumbai

Address – Maneckji Wadia Building, Nanik Motwani Marg, Fort, Mumbai 400023.

Branch Code – 60

Bank & Branch Code – 400240015

Account No – 00600110000763

Account type – CC

IFSC Code – HDFC0000060

E-mail with necessary attachment of 1 and 2 above to be send to tushar.patil@tatapower.com & with copy to vivek.mittal@tatapower.com before “Last date and time for Payment of Tender Participation Fee”.

Interested bidders to submit Tender Participation Fee and Authorization Letter before Last date and time as indicated above after which link from Tata Power E-Tender system (Ariba) will be shared for further communication and bid submission.

Please note all future correspondence regarding the tender, bid submission, bid submission date extension, Pre-bid query etc will happen only will be strictly done only with interested bidders who have done the above steps in time with Authorized Person only through Tata Power E-Tender system (Ariba). User manual to guide the bidders to submit the bid through e-Tender system (Ariba) is also enclosed.

No e-mail or verbal correspondence will be responded. All communication will be done strictly with the bidder who have done the above steps (Payment of tender fee and submission of letter with requisite details) to participate in the Tender.

Also, it may be strictly noted that once date of “Last date and time for Payment of Tender Participation Fee” is lapsed no Bidder will be sent link from Tata Power E-Tender System (Ariba). Without this link vendor will not be able to participate in the tender. Any last moment request to participate in tender will not be acknowledged.

Any payment of Tender Participation Fee / EMD by Bidder who have not done the pre-requisite within stipulated timeline will not be refunded.

Also, all future corrigendum's to the said tender, if any, will be informed on Tender section on website <https://www.tatapower.com>

Earnest Money Deposit (EMD) is not to be submitted now and is required at a later stage along with tender submission in the form of Bank Guarantee and NEFT.

SECTION-E

Annexure-1: Technical Prequalification Requirement

| Pre- Qualification requirement (PQR) | | | | |
|--------------------------------------|------------------------------|--|---|-----------------|
| To be filled by Tata Power | | | | |
| BI | Parameter | Tata Power Requirement | Documents to be submitted by vendor to ascertain meeting of Pre- Qualification Requirement | Bidder response |
| 1 | 2 | 3 | 4 | 5 |
| (A) | Infrasructure | Bidder must be an OEM of Transmission line Hardware of 220 kV with manufacturing facility / assembly in India. | Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter. | |
| (B) | Supply and Experinece | <p>Bidder should have executed at least one single contract during last five years for quantity equivalent to tender / bid. The above quantity supplied shall be in satisfactory service for last two years as on date of bid submission.</p> <p>Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.</p> | <p>Supply List & Performance Certificates from the utilities / clients</p> <p>Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.</p> | |
| (C) | Type test | <p>The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the equipment / material of the same design.</p> <p>The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test can be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC).</p> <p>In case the type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, then type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material.</p> | <p>Type Test Report.</p> <p>Undertaking that there is no change in design / material of construction (MOC) if Type Test Report older than 5 years but less than 10 years prior to date of bid opening has to be considered (if applicable)</p> <p>Undertaking that type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before despatch of the equipment / material, in case type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, (if applicable)</p> | |
| (D) | Commercial Capability | Average Annual Turnover of the bidder for last 03 years shall not be less than 200 Lakhs. | Profit and loss statement for the last three financial years with duly signed & stamped by CA firm. | |
| Note: | | <p>Further to above PQR, In case the bidder has a previous association with any of Tata Power Group companies for similar products and services, the performance feedback of the bidder by the Tata Power Group companies shall be considered for evaluation purpose, at the discretion of Tata Power, irrespective of performance certificates issued by any third organization.</p> | | |

| Price bid format_CC25TP050_Supply of GI Hardware Fittings for upgradation of 110 kV Kalwa Kalyan Line | | | | Vendor to fill | |
|--|-------------------------------------|------------|-------------|-----------------------|--------------------|
| Sr No | Item | Qty | Unit | Rate | Basic total |
| 1 | D Shackle ,(120 KN) | 10000 | EA | | 0 |
| 2 | Traingular Yoke plate (120 KN) | 2700 | EA | | 0 |
| 3 | Ball & Clevies, (120 KN) | 2800 | EA | | 0 |
| 4 | Socket Clevies (120 KN) | 3800 | EA | | 0 |
| | Total basic price | | | | 0 |
| | GST@ 18% | | | | 0 |
| | Total All inclusive of Taxes | | | | 0 |