

NOTICE INVITING TENDER

The Tata Power Company Limited Invites Tenders (Two-Part Bidding Process), from interested and eligible Vendors for the following Works required for its various Transmission Receiving Stations.

A. Summary of the tendered packages:

Tender Enquiry No.	Work Description	EMD (Rs.)	Tender Participation Fee (Rs.)	Last date and time for Payment of Tender Participation Fee*
CC27NK001	Supply and Supervisory services of 800 kVA, 33kV & 22kV Station Transformers for Backbay & Ambernath Receiving Station	1,00,000/-	Rs. 2,000/-	1500 Hrs. 22 nd April 2026

Interested bidder is strongly advised not to wait by above time and purchase the tender immediately to get the link for bid submission. This will enable them to communicate/raise queries against the subject tender in time.

For additional technical details and Pre-qualification criteria for the subject works please refer section C below.

B. Guidelines for Participating:

Interested and eligible vendors can participate by submitting the following up to 1500 hours on **Wednesday – 22nd April 2026**.

1. Payment of non-refundable Tender Fee, as indicated in table above to be paid by direct deposit in following bank account

Beneficiary Name – The Tata Power Co. Ltd.

Bank Name – HDFC Bank Ltd.

Branch Name – Fort Branch, Mumbai

Address – Maneckji Wadia Building, Nanik Motwani Marg, Fort, Mumbai 400023.

Branch Code – 60

Bank & Branch Code – 400240015

Account No – 00600110000763

Account type – CC

IFSC Code – HDFC0000060

2. Submission of duly signed and stamped Authorization Letter indicating name of authorized person, contact number and e-mail id (mandatory) on Vendor's letterhead. The letter shall also mandatorily include payment details of Tender fee and Tender Reference no **CC27NK001**.

Authorization Letter along with proof of submission of tender fee should be e-mail to **Mr. Nithishkumar Kuppusami** (n.kuppusami@tatapower.com) and copy to **Ms. Vaishali Kachare** (vaishali.Kachare@tatapower.com)

Note: - Once the above-mentioned documents are received, detailed RFP shall be issued through our e-tender system.

3. It is clarified that Bid Guarantee/EMD as mentioned in section "A" above, is not required to be submitted at this stage, and it will be required to be submitted in the form of Bank guarantee at the time of Bid Submission.

C. Addition technical details: Prequalification Criteria (Technical & Commercial):

Pre-qualification Requirement Criteria			
1	2	3	4
S No	Parameter	Tata Power Requirement	Documents To be submitted by Vendor to ascertain meeting of Pre-qualification requirement
1	Infrastructure	Bidder shall be an OEM of "Station (Distribution) Transformer" with manufacturing facility / assembly in India. The bidder must have in-house routine and acceptance testing facilities for acceptance as per relevant IS/IEC.	Self-undertaking to be submitted in this regard. Tata Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.
2	Supply & Experience	<p>Bidder shall have supplied from India minimum "14 Nos" Mineral Oil (MO) Station Transformer of 33 kV, 800 KVA or higher capacity rating in last 10 years. Minimum 2 no. of MO Station transformer of same rating or higher capacity should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.</p> <p>Indian Subsidiaries of global companies having plant in India are also eligible to bid if the qualification requirements stated above are met independently or in combination with the parent company. Declaration from parent company needs to be submitted.</p>	<p>Supply List & Performance Certificates from the utilities / clients</p> <p>Self-undertaking to be submitted in this regard. TATA Power reserves the right to inspect the said manufacturing facility as a proof of compliance to this parameter.</p>
3	Type Test	<p>The bidder shall submit Type test reports obtained from NABL/ International Accredited Lab for the equipment / material offered. The type tests should have been conducted on the same ratings (22 KV & 33 KV) or higher rating MO Station Transformer of the same design.</p> <p>The type tests should have been conducted within 5 years prior to the date of bid opening. Time period for type test can be extended by another 5 years as a special case, if there is no change in design / material of construction (MOC).</p> <p>In case the type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, then type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before dispatch of the equipment / material.</p>	<p>Type Test Report.</p> <p>Undertaking that there is no change in design / material of construction (MOC) if Type Test Report older than 5 years but less than 10 years prior to date of bid opening has to be considered (if applicable)</p> <p>Undertaking that type test shall be carried out for the offered equipment / material from NABL / International Accredited Lab without any cost implication to the owner and the Type Test reports shall be submitted before dispatch of the equipment / material, in case type test reports furnished are not for the quoted equipment / material but for the equipment / material with higher voltage class and/or different capacity, (if applicable)</p>

4	EPC Experience (If applicable)	In case the package involves installation & commissioning of the equipment / material, then the bidder shall have installed and commissioned 7 nos. Mineral Oil (MO) Station Transformer of 33 kV, 800 KVA or higher capacity rating and should have been in satisfactorily commercial operation for a minimum period of two years as on the date of bid opening.	Performance Certificates from the utilities / clients
5	Capability of Handle Job financially if awarded	Average Annual turnover of the bidder for last three years shall not be less than INR 1 Crore.	Profit and Loss Statements, Balance Sheet, Cash Flow Statements for the Three (3) preceding financial years duly audited and approved by Authorized Audit Firm / CA.

Note: Above Pre-qualification details need not be submitted at this stage. These shall be required to be submitted along with bid submission. At this stage, Interested Vendors who fulfill above criteria need to participate in tender by paying tender fee and submitting authorization letter as detailed in section "B" above.

D. Price Bid Format: (BOM)

Package Name - 800 kVA, 33/0.415 kV, Dyn11 OIL FILLED DISTRIBUTION TRANSFORMER @ Backbay RSS

Sr No.	Item Description	Unit	Quantity
1	Design, manufacture, factory testing, packing, route survey, delivery of 3 phase, Oil filled, 50 Hz, 800 kVA, 33/0.415 kV, Dyn11 transformer including all accessories as per the specific and general requirements and complete with bushings, cable box, conservator etc. with transformer Oil that includes (filling of transformer, conservator and radiators + 10% extra)	EA	2
2	Supply of spares as per Section B clause no. 11.1 (Qty 01 for each type)	Set	1
3	Services for commissioning of Transformer (3 phase, 50 Hz, 800kVA, 33/0.415 kV Dyn11)		
3.1	Supervisory services for unloading, erection, installation, testing and commissioning of transformer being supplied as above	Days	6

Package Name - 800 kVA, 22/0.415 kV, Dyn11 OIL FILLED DISTRIBUTION TRANSFORMER @ Ambarnath RSS

Sr No.	Item Description	Unit	Quantity
--------	------------------	------	----------

1	Design, manufacture, factory testing, packing, route survey, delivery of 3 phase, Oil filled, 50 Hz, 800 kVA, 22/0.415 kV, Dyn11 transformer including all accessories as per the specific and general requirements and complete with bushings, cable box, conservator etc. with transformer Oil that includes (filling of transformer, conservator and radiators + 10% extra)	EA	1
2	Supply of spares as per Section B clause no. 11.1 (Qty 01 for each type)	Set	1
3	Services for commissioning of Transformer (3 phase, 50 Hz, 800kVA, 22/0.415 kV Dyn11)		
3.1	Supervisory services for unloading, erection, installation, testing and commissioning of transformer being supplied as above	Days	3

It may be noted that all future correspondence will be strictly done only with Interested Vendors who have done the above steps (As mentioned in section "B") in time with Authorized Person, and only through Tata Power E-Tender System.
